

## Product Guide Specification

Specifier Notes: This product guide specification is written according to the Construction Specifications Institute (CSI) 3-Part Format, including *MasterFormat*, *SectionFormat*, and *PageFormat*, as described in *The CSI Construction Specifications Practice Guide*.

This section must be carefully reviewed and edited by the Architect to meet the requirements of the project and local building code. Coordinate this section with other specification sections and the Drawings. Delete all "Specifier Notes" after editing this section.

Section numbers and titles are from *MasterFormat 2014 Update*.

### SECTION 11 61 13

#### ACOUSTICAL SHELLS

Specifier Notes: This section covers StageRight "Sonata" acoustic shells. Consult StageRight for assistance in editing this section for the specific application.

#### PART 1 GENERAL

##### 1.1 SECTION INCLUDES

- A. Acoustic shells.

##### 1.2 SUBMITTALS

Specifier Notes: Edit submittal requirements as necessary. Delete submittals not required.

- A. Comply with Section 01 33 00 – Submittal Procedures.
- B. Product Data: Submit manufacturer's product data, including the following:
  1. Detailed specification of construction and fabrication.
  2. Description of operations, including step by step set-up and take-down tasks.
  3. Complete list of deviations from specifications.

- C. Shop Drawings: Submit manufacturer's shop drawings, including plans, elevations, sections, and details, indicating dimensions, tolerances, materials, components, fabrication, fasteners, hardware, finish, options, and accessories.
- D. Samples: Submit 2 sets of manufacturer's samples for color selection or verification of acoustical reflective material.
- E. Manufacturer's Project References: Submit manufacturer's list of successfully completed acoustic shell projects, including project name and location, name of architect, and type and quantity of acoustic shells furnished.
- F. Contract Closeout Submittals: Submit contract closeout submittals as follows:
  - 1. Operating and maintenance manuals, including the following:
    - a. Operation, maintenance, adjustment, and cleaning instructions.
    - b. Troubleshooting guide.
    - c. Parts list.
    - d. Detailed information required for Owner to properly operate and maintain acoustic shells.
  - 2. Setup configuration layout and details to permit verification of safety design requirements.
  - 3. Project record documents.
- G. Warranty Documentation: Submit manufacturer's standard warranty.

### **1.3 QUALITY ASSURANCE**

- A. Manufacturer's Qualifications: Minimum 20 years of experience in the manufacturing of acoustic shells.
- B. Manufacturer's Quality Control:
  - 1. Manufacturer shall make or have made, under their control, all parts comprising complete acoustic shells.
  - 2. Maintain test and inspection procedures, to assure uniform high quality of all raw materials and finished product.
  - 3. Manufacturer shall have capacity and facilities to furnish quality and quantity required without delaying the Work.
- C. Welder's Qualifications: AWS certified for each type of weld required.

### **1.4 DELIVERY AND STORAGE**

- A. Delivery Requirements: Deliver acoustic shells to site in manufacturer's original, unopened containers and packaging, with labels clearly identifying product name and manufacturer.
- B. Storage Requirements: Store acoustic shells at location designated by the Owner.

### **1.5 WARRANTY**

- A. Warranty Period: 1 year from date of delivery.

## **PART 2 PRODUCTS**

### **2.1 MANUFACTURERS**

- A. Manufacturer: StageRight, 495 Pioneer Parkway, Clare, Michigan 48617. Toll Free 800-438-4499. Website www.stageright.com. E-mail stageright@rogersgrp.com.
- B. Substitutions: Not permitted.
- C. Single Source: Provide all components of acoustic shells by single manufacturer.

### **2.2 SYSTEM DESCRIPTION**

- A. Acoustic Shells: "Sonata".
  - 1. Moveable wall towers and ceiling that reflect a maximum range of audible frequencies.
  - 2. Folds in half for transport and storage.

### **2.3 TOWERS, SIDE AND BACK WALLS**

- A. Towers:
  - 1. Self-supporting, sound-reflecting towers with counterweighted, nesting bases.
  - 2. Radiused panels mounted to vertical tower.

Specifier Notes: Specify panel height. Standard heights are from 14 feet to 16 feet in 6-inch increments. Consult StageRight for custom heights.

- B. Panel Height: [14'-0"] [14'-6"] [15'-0"] [15'-6"] [16'-0"] [\_\_\_\_\_].
- C. Panel Width: 5 feet.
- D. Base:
  - 1. Fully counterbalanced to safely move towers about stage.
  - 2. Castors: 4 swivel casters, 2 locking, 5-inch diameter.
- E. Top Panel Movement:
  - 1. Springs:
    - a. 4 gas springs assist with top panel movement.
    - b. Safety Factor: Allow 3 gas springs to safely control movement.
  - 2. Handle:
    - a. Integral handle to raise and lock top panels.
    - b. Separate Pole: Not acceptable.

Specifier Notes: Finished edging is optional. Specify finish. Delete if not required.

- F. Finished Edging:
  - 1. Finish: [Black] [Matching wood grain].

- G. Safety Instructions: Affix to tower in plain view instructions pertaining to safe handling and operation of towers.
- H. Tower Hardware:
  1. Hardware necessary to safely transport towers to and from storage and lock into place when in use position.
  2. Frame: Modular, 2-inch OD steel tube.
  3. Counterweight: Steel plates stacked in enclosed tamper-proof weight box.
  4. Casters: 5-inch diameter.
  5. Finish: Black powder coat.

Specifier Notes: Overhead sound reflectors are optional. Delete if not required.

## 2.4 OVERHEAD SOUND REFLECTORS

- A. Sound reflective panels supported from existing stage rigging, including integral hardware for single-pipe storage without interference with adjacent stage equipment.
- B. Suspended from truss batten.
- C. Panel Width Dimensions: Match approximate spacing of rigging cable attachment to pipe batten.
- D. Storage:
  1. Allow entire row to be rotated to storage position at 1 time by 2 people.
  2. No tools necessary to rotate panels for storage.
  3. Maximum Storage Space: Typically 5 inches to 7 inches on each side of pipe batten centerline, depending on ceiling and light fixture configuration.
- E. Each Row of Overhead Panels: Equip with necessary hardware to hang from recommended 1-1/2-inch schedule 40 pipe batten.
- F. Hardware:
  1. Permit angular adjustment from horizontal plane to 40 degrees.
  2. Capability of locking panels in a vertical position, so they may be stored on battens in stage loft.
- G. Safety Instructions: Provide instructions pertaining to safe handling of overhead panels.

Specifier Notes: Edit the Ceiling Schedule for the custom acoustic shell for the specific application.

- H. Ceiling Schedule:
  1. Row 1: \_\_\_\_\_ deep by \_\_\_\_\_ wide, tapered ends.
    - a. \_\_\_\_\_ hanger points, \_\_\_\_\_ light fixtures.
  2. Row 2: \_\_\_\_\_ deep by \_\_\_\_\_ wide, tapered ends.
    - a. \_\_\_\_\_ hanger points, \_\_\_\_\_ light fixtures.
  3. Row 3: \_\_\_\_\_ deep by \_\_\_\_\_ wide, tapered ends.
    - a. \_\_\_\_\_ hanger points, \_\_\_\_\_ light fixtures.

4. Row 4: \_\_\_\_\_ deep by \_\_\_\_\_ wide, tapered ends.
  - a. \_\_\_\_\_ hanger points, \_\_\_\_\_ light fixtures.

## 2.5 PANELS

- A. Sound-reflecting laminated panels.
- B. Panel Thickness: 1-5/8 inches.
- C. Exposed Face:
  1. 0.060-inch-thick, Formica high-pressure laminate.
  2. Fire Rated: Class C.
- D. Substrate: 1/8-inch tempered hardboard each side of core.
- E. Backing:
  1. Natural finish, high-pressure laminate.
  2. Fire Rated: Class C.
- F. Core:
  1. 3/8-inch cell, 80-80-15 phenolic-impregnated, cellulose honeycomb.
  2. Thickness: 1.3 inches.
- G. Frame:
  1. Exposed Edges of Individual Panels: Protect by extruded aluminum frame/edging with injected molded corners.
  2. Continuous Edge Slot: Allow mechanical fastener attachment to tower structural frame.
- H. Adhesive:
  1. High-solid, pressure-cured, moisture-activated, urethane structural adhesive.
  2. Contact-Type Adhesives: Not acceptable.
- I. Exterior Surface Shape: Bowed to 10'-0" radius.
- J. Weight:
  1. Minimum of 2-1/2 lbs per square foot, excluding frame weight.
  2. Panels of Less Weight: Deemed insufficient to reflect low-frequency sound; not acceptable.
- K. Finish:
  1. Panel Face Surface: No exposed fasteners.
  2. Face Finish: Matte.
  3. Panel Edges: Flat black, anodized.
  4. Panel Face Color: Color will be selected from Formica standard colors by Owner's representative.

## 2.6 LIGHTING

Specifier Notes: Specify lamps.

- A. Lamps: [ETC Source 4 PAR fixture] [Future light 1000 fixture].
- B. Owner will have a choice of electrical connections from a list available from manufacturer.
- C. Connector Strip:
  - 1. Provide 1 UL-listed connector strip for each row of ceiling panels.
  - 2. Circuited as indicated on the Drawings.

## 2.7 STORAGE

Specifier Notes: Edit the following sentence for storage for the specific application.

- A. Acoustic Shell Storage: Store in an area no larger than \_\_\_\_\_ wide by \_\_\_\_\_ deep by 9'-2-1/2" high.
  - 1. Shell Bases: Nest compactly.
  - 2. Bottom Filler Panel: Removable and self-storing to allow compact nesting of towers in storage position.
  - 3. Folds down easily for transport.
  - 4. External Mover Device: Not required.

## PART 3 EXECUTION

### 3.1 INSTALLATION

- A. Three sets of detailed shop drawings and/or instructions shall be furnished by the manufacturer at installation.

Specifier Notes: Delete one of the following two paragraphs.

- B. Installation Supervised by Manufacturer: Manufacturer shall supply 1 factory-trained and certified representative to supervise installation of acoustic shells.
- C. Installation Performed by Manufacturer: Manufacturer shall install acoustic shells.

### 3.2 TRAINING

- A. Provide instruction and training of Owner's personnel in the operation and maintenance of acoustic shells.
- B. Provide instruction and training by factory-trained and certified representative of manufacturer.

**END OF SECTION**